

David Snyder - comment on revision to R317-4

From: Kate Johnson
To: David Snyder
Date: 9/13/2012 8:07 AM
Subject: comment on revision to R317-4
CC: Leah Ann Lamb

Hi Dave: I asked Jim Martin to review the proposed new rule, since he's been working on some changes in our rules relative to sewer issues. His suggestion related to a minor change to Table 2. For footnote c, where there is a reference to R309-600, the suggestion is to change that to:

All distances will comply with R309-600, which specifies 100 ft separation in protected aquifers, and a location outside of zone 2 in unprotected aquifers. Protected/unprotected aquifers are further defined in R309-600. More specific information can also be obtained from Division of Drinking Water staff at 801-536-4200.

or something along those lines. thx